

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

# PAMESA GRUPO EMPRESARIAL S.L.U.

CAMINO ALCORA S/N 12550, ALMAZORA-CASTELLON, Spain

For the following product(s):

## Porcelain:

ECOCERAMIC, S.L.U., GEOTILES, S.L.U., NAVARTI CERÁMICA, S.L.U., PRISSMACER CERÁMICA, S.L.U., PAMESA CERÁMICA COMPACTTO, S.L.U., TAU CERAMICA SOLUTIONS, S.L.U.



The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-06088

Valid from: May 1, 2021 to April 30, 2022

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President  
SCS Global Services

2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA

**FloorScore®**

## **2021 Renewal Certification Assessment**

---

*SCS Environmental Certification Services*

Prepared for:

**PAMESA GRUPO EMPRESARIAL S.L.U.**

**Porcelain Tile**

*Manufactured in Almazora, Castellon, Spain*

**Project Work Order: #PAM-20-02**

**April 23, 2021**



## FloorScore® Renewal Certification Assessment

---

SCS Global Services, Environmental Certification Services completed a renewal FloorScore certification assessment of PAMESA GRUPO EMPRESARIAL S.L.U's Porcelain Tile products manufactured in Castellon, Spain. The lead auditor has completed a full assessment of the quality management assessment of each manufacturing site and product emissions review to determine conformance to SCS EC 10.3 – 2014 V4.0 Indoor Air Quality Performance Standard and CA 01350 (Standard Method v1.2, effective April 1, 2017). The results of the assessment are included within this assessment report.

This certification assessment has been completed in accordance with SCS' quality management system, ISO 19011 standard auditing practices, ISO/IEC 17065 and has been approved by the program manager. If there is a disagreement with the certification decision, please contact the program manager/quality manager directly.



Michael Hubbell, April 12, 2021  
Lead Auditor  
mhubbell@scsglobalservices.com



Jenilee Hsu, April 23, 2021  
Flooring Program Manager  
jhsu@scsglobalservices.com

## EXECUTIVE SUMMARY

### ASSESSMENT SCOPE

PAMESA GRUPO EMPRESARIAL S.L.U.'s Porcelain Tile assessment scope is detailed in the work order PAM-20-02.

### Changes to Client's Company Name

A change of scope was required to remove the previous client's company name, and update with the correct company name.

PREVIOUS COMPANY NAME	UPDATED COMPANY NAME
PAMESA CERAMICA, SA	PAMESA GRUPO EMPRESARIAL S.L.U

### Changes to Client's Product Lines

A change of scope was required to change the names of the existing product lines.

CERTIFICATE NUMBER	PRODUCT LINE NAMES REMOVED	PRODUCT LINE NAMES ADDED
SCS-FS-06088	Azulejos Foset, Ceramic Tile International slu, Geologica Tile, Navarti, Pamesa Ceramica, Tau Ceramica	ECOCERAMIC, S.L.U., NAVARTI CERÁMICA, S.L.U., PRISSMACER CERÁMICA, S.L.U., TAU CERAMICA SOLUTIONS, S.L.U., GEOTILES, S.L.U., PAMESA CERÁMICA COMPACTTO, S.L.U.

### INDOOR AIR QUALITY CERTIFICATION SUMMARY

The following table details the conformance for products that have met FloorScore® product certification requirements. Products that have met FloorScore® certification also comply with the following criteria: USGBC LEED 2008, 2009 and v4 for Low-Emitting Materials (Flooring); Collaborative for High Performance Schools (CHPS) 2009 Criteria, EQ2.2.3; ANSI/ASHRAE/USGBC/IES Standard 189.1-2014, Section 8.4.2.3: Floor Covering Materials; BREEAM International and BREEAM UK; Green Guide for Health Care 2.2 EP 3.3 and EQ 4.3; and WELL Building Standard 4.3.a: Air.

PRODUCT CATEGORY	PRODUCT LINE(S)	QUALIFICATIONS	CERTIFICATE NUMBER	CERTIFICATION PERIOD
Porcelain Tile	ECOCERAMIC, S.L.U., NAVARTI CERÁMICA, S.L.U., PRISSMACER CERÁMICA, S.L.U., TAU CERAMICA SOLUTIONS, S.L.U., GEOTILES, S.L.U., PAMESA CERÁMICA COMPACTTO, S.L.U.	TVOC Range: 0.5 mg/m <sup>3</sup> or less	SCS-FS-06088	May 1, 2021 – April 30, 2022

## PRODUCT ASSESSMENT SUMMARY

The following table indicates if a Non-Conformance Report (NCR) / Opportunity for Improvement (OFI) /New Information Request (NIR) is issued based on deficiencies found in the documentation or other supplemental information provided to meet both Standard Method v1.2 and the Quality Management System requirements. All NCRs must be closed before certification may be issued.

NCR/ OFI/ NIR-#	STANDARD REQUIREMENT	AUDITOR FINDINGS	DUE DATE	STATUS
NIR-19-01	SCS-EC10.3-2014 V4.0-Section 6.6	The Onsite Audit for both sites have not yet been conducted due to auditor availability and travel restrictions due to COVID-19. The onsite audit will be scheduled once it is safe to resume travel.	April 30, 2022	Open
NIR-19-02	SCS-EC10.3-2014 V4.0-Section 6.2	Testing of product manufactured at Tau (Onda) has not been submitted.	May 31, 2021	Pending

## MANUFACTURING ONSITE AUDIT SUMMARY

The table below indicates the entire scope of applicable site audits, the status of site audits completed, conformance status, and rationale for site audit selection for initial and renewal years.

MANUFACTURING SITE	TO BE COMPLETED BY	STATUS OF NCR/NIR	AUDITOR RATIONALE
Pamesa Ceramica Almazora Castellon Spain	April 30, 2022	See NIR-19-01	Due to limited auditor capacity, the onsite audits required for initial certification were not able to be scheduled prior to issuing certification. The auditor will work with the client to ensure that the first audit is scheduled within the initial year of certification. This NIR is extended due to Covid-19 travel restrictions.
Tau Ceramica Onda-Castellon, Spain			

## 1.0 Product Category Assessment

The following tables provide a progressive review on how products were selected to represent the emission profile for the product category, actual emissions results, and overall product certification results.

### 1.1 PRODUCT TESTING SAMPLE SELECTION

PAMESA GRUPO EMPRESARIAL S.L.U has demonstrated low emission results in the past. As a result, no additional testing will be required during the 2024 renewal.

### 1.2 PRODUCT EMISSIONS RESULTS

The table below summarizes the product emissions history results for the individual volatile organic compounds (VOCs) tested for compliance to CA Specification 01350 (Standard Method v1.2, effective April 1, 2017) private office and school classroom parameters when modeled as flooring.

#### 1.2.1 PORCELAIN TILE

MANUFACTURING SITE	PRODUCT LINE	LAB REPORT NUMBER AND DATE	CREL VOCs	EF ( $\mu\text{g}/\text{m}^2$ ) at 96 hrs	PRIVATE OFFICE* RESULTS	SCHOOL CLASSROOM** RESULTS	TVOC RANGE
Almazora-Castellon	Koncept Gris	392-2020-00054701 - 3/3/2020	Not Detected	-	PASS	PASS	
Almazora-Castellon	Koncept Gris	392-2020-00054701 - 3/3/2020	TVOC	-	-	-	0.5 mg/m <sup>3</sup> or less
Almazora-Castellon	Cromat Perla	392-2020-00054702 - 3/3/2020	Not Detected	-	PASS	PASS	
Almazora-Castellon	Cromat Perla	392-2020-00054702 - 3/3/2020	TVOC	-	-	-	0.5 mg/m <sup>3</sup> or less

\*Key modeling parameters for the private office scenario include an air flow rate of 20.7 m<sup>3</sup>/hr and flooring surface area of 11.15m<sup>2</sup>.

\*\*Key modeling parameters for the school classroom scenario include an air flow rate of 191 m<sup>3</sup>/hr and a flooring surface area of 89.2m<sup>2</sup>.

The results for Pamesa Ceramica's Porcelain Tile products manufactured in Almazora Castellon Spain demonstrate that all 35 targeted CREL VOCs listed in CDPH/EHLB Standard Method V1.2 are not detected. Therefore, these products are considered of **Minimal Concern**. The TVOC results also demonstrate a TVOC range of 0.5 mg/m<sup>3</sup> or less.

## 1.3 Quality Management System

The table below includes a review of the ongoing maintenance of the manufacturer's quality management system in accordance to SCS EC10.3-2014.

### 1.3.1 ALMAZORA, CASTELLON, SPAIN

	REQUIREMENT	SUPPORTING DOCUMENTATION	AUDITOR KEY FINDINGS	CONFORMANCE ISSUE
1	<b>QMS Certification</b> Valid ISO 9001 or comparable certification was submitted (if applicable)	1.2.6. UNE EN ISO 9001 Approval cert.pdf	The client is ISO 9001 certified, valid until July 31, 2021.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR
2	<b>Internal/External Audits</b> Evidence of no outstanding NCRs were provided.	1.2.7. February Internal ISO Audit 2021.pdf  1.2.8A Non Conformance Report, IA 2021.pdf  1.2.8B Actions to Non Conformance Report, IA 2021.pdf	The client has submitted an internal audit. There were two non-conformances , both closed with corrective action provided.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR
3	<b>Production Flow Chart</b> [Reference: SCS-EC10.3-2014-Section 6.5]	Pamesa_2021_FS_Renewal_DRF_auditor.docx	The client has indicated no changes to this aspect of the Quality Management System.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR
4	<b>Production Variability</b> [Reference: SCS-EC10.3-2014-Section 6.5]	Pamesa_2021_FS_Renewal_DRF_auditor.docx	The client has indicated no changes to this aspect of the Quality Management System.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR
5	<b>Product Line Identification and Traceability</b> [Reference: SCS-EC10.3-2014-Section 6.5]	GlobalEPD 002-013 DAP PAMESA PORCELAIN.pdf	The client has provided the traceability procedure.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR
6	<b>Production Control</b> [Reference: SCS-EC10.3-2014-Section 6.5]	1.1.10. Quality claim system and incident resolution (Representative).pdf	The client has provided the customer complaint procedure.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR

### 1.3.2 ONDO-CASTELLON, SPAIN

	REQUIREMENT	SUPPORTING DOCUMENTATION	AUDITOR KEY FINDINGS	CONFORMANCE ISSUE
1	<b>QMS Certification</b> Valid ISO 9001 or comparable certification was submitted (if applicable)	Pamesa_2021_FS_Renewal_DRF_auditor.docx	The site is not ISO certified but has implemented a Quality Management System.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR
2	<b>Internal/External Audits</b> Evidence of no outstanding NCRs were provided.	GlobalePD 002-033 DAP TAU PORCELAIN.pdf (Section 4.1)	The client has provided a production flow chart.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR
3	<b>Production Flow Chart</b> [Reference: SCS-EC10.3-2014-Section 6.5]	2.7 TAU Internal Audit.pdf	An internal audit was submitted. There was one non-conformance finding but was closed with corrective action.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR
4	<b>Production Variability</b> [Reference: SCS-EC10.3-2014-Section 6.5]	Pamesa_2021_FS_Renewal_DRF_auditor.docx	The client has indicated no changes to this aspect of the Quality Management System.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR
5	<b>Product Line Identification and Traceability</b> [Reference: SCS-EC10.3-2014-Section 6.5]	TAU STICKER.pdf	The client has a traceability and identification procedure.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR
6	<b>Production Control</b> [Reference: SCS-EC10.3-2014-Section 6.5]	1.1.10. Quality claim system and incident resolution (Representative).pdf	The client has provided the customer complaint procedure.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR



## 1.5 FloorScore® Logo Review

The table below includes a review of the ongoing FloorScore® logo usage

	REQUIREMENT	SUPPORTING DOCUMENTATION	AUDITOR KEY FINDINGS	CONFORMANCE ISSUE
1	<b>Logo Use-Website</b> Are SCS Indoor Air Quality logos used on the company website? (If yes, provide a link to the website.)	<a href="https://www.pamesa.com/CORPORATIVO.html">https://www.pamesa.com/CORPORATIVO.html</a>	The client uses the logo appropriately in this aspect.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR
2	<b>Logo Use-Marketing Collateral</b> Are SCS Indoor Air Quality logos used on “off-products” such as brochures, price lists, or leaflets? (If yes, provide a sampling of logos used on off-products.)	1.1.6 Technical Data Sheet Logo Use ok.pdf	The client uses the logo appropriately in this aspect.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR
3	<b>Logo Use-On Product Packaging</b> Are SCS Indoor Air Quality logos used on products such as product packaging or labels? (If yes, provide an example of a logo used on products.)	Pamesa_2021_FS_Renewal_DRF_auditor.docx	The client does not use the logo in this aspect.	<input checked="" type="checkbox"/> No issue <input type="checkbox"/> OFI <input type="checkbox"/> NIR <input type="checkbox"/> NCR

## APPENDIX

### A.1 Renewal Audit Recommendations

#### A.1.1 Renewal Sample Selection

The following table represents suggested sample selections for emissions testing. The frequency and required number of samples is dependent on the quality management systems review per manufacturing site and emissions history review completed during each renewal assessment by the auditor.

PRODUCT LINE	PRODUCT MODEL/SKU NUMBER	Renewal YEAR	AUDITOR RATIONALE
Pamesa Ceramica	11.5mm	2024	The results for Pamesa Ceramica's Porcelain Tile products manufactured in Almazora Castellon Spain demonstrate that all 35 targeted CREL VOCs listed in CDPH/EHLB Standard Method V1.2 are not detected. Therefore, these products are considered of Minimal Concern and require renewal testing every four years.